



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6340BN3862

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Samson AG Weismüllerstraße 3, D-60314 Frankfurt am Main
Distributor <i>Vertreiber</i>	Samson AG Weismüllerstraße 3, D-60314 Frankfurt am Main
Product Category <i>Produktart</i>	valves for drinking water: thermostatic control valve (6340)
Product Description <i>Produktbezeichnung</i>	three-way valve (with control thermostat) for the distribution respectively supply of cold water in storage reservoir or thermal transmitter for making hot drinking water
Model <i>Modell</i>	Typ 43-3
Test Reports <i>Prüfberichte</i>	laboratory control test: from 07.03.2022 (TZW) type testing: TA 036/11 from 09.01.2012 (TZW) UBA-Guideline: K-340122-21-Kr/sg from 15.02.2021 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DVGW 31-24/2-2007 (31.10.2002) UBA BWGL-Metalle (14.05.2020) UBA Übergangsregelung KTW-BWGL (10.07.2020) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	20.12.2027 / 22-0460-WNV

28.09.2022 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 15	
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 20	
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 25	
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 32	
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 40	
Typ 43-3	pressure rating: PN 10 nominal diameter: DN 50	