

# **Certificate of Compliance**

**Certificate:** 1675804 **Master Contract:** 173246 (LR 54227)

**Project:** 70136714 **Date Issued:** 2017-05-23

**Issued to:** Samson AG

Mess- Und Regeltechnik Weismuellerstrasse 3 Frankfurt, 60314 GERMANY

**Attention: Tomislav Varga** 

The products listed below are eligible to bear the CSA Mark shown



**Issued by:** 

R Papiah

#### **PRODUCTS**

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

#### Ex ia IIC T6

Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Type 4 Enclosure

Model 3730-53 FOUNDATION Fieldbus Positioner, Temperature Code T6 at ambient of  $-40^{\circ}$ C to  $+60^{\circ}$ C, T5 at  $-40^{\circ}$ C to  $+70^{\circ}$ C, T4 at  $-40^{\circ}$ C to  $+80^{\circ}$ C; Intrinsically safe when installed per Samson AG installation drawing EB8384-5 EN.

**CLASS 2258 03** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems - For Hazardous Locations

Ex nL IIC T6

Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III; Type 4 Enclosure

Model 3730-53 FOUNDATION Fieldbus Positioner, Temperature Code T6 at ambient of -40°C to +60°C, T5 at -40°C to +70°C, T4 at -40°C to +80°C; Energy-limited (Non-incendive) when installed per Samson AG installation drawing EB8384-5 EN.



 Certificate:
 1675804 (LR 54227)
 Master Contract:
 173246

 Project:
 70136714
 Date Issued:
 2017-05-24

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

#### Ex nA II T6

Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III; Type 4 Enclosure

Model 3730-53 FOUNDATION Fieldbus Positioner, Temperature Code T6 at ambient of  $-40^{\circ}$ C to  $+60^{\circ}$ C, T5 at  $-40^{\circ}$ C to  $+70^{\circ}$ C, T4 at  $-40^{\circ}$ C to  $+80^{\circ}$ C. Refer to installation EB 8384-5 EN for electrical ratings.

#### **Condition of acceptability**

The Model 3730-53 must be installed per SAMSON AG installation drawing EB8384-5 EN.

#### APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966	-	Enclosures for Use in Class II, Groups E, F and G Hazardous
		Locations
CAN/CSA-C22.2 No. 94-M91	-	Special Purpose Enclosures
CSA Std C22.2 No. 142-M1987	-	Process Control Equipment
CAN/CSA-C22.2 No.157-92	-	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous
		Locations
CSA Std C22.2 No. 213-M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2
		Hazardous Locations
CAN/CSA-E60079-0:02	-	Electrical Apparatus for Explosive Atmospheres, Part 0 - General
		Requirements
CAN/CSA-E60079-11:02	-	Electrical Apparatus for Explosive Atmospheres, Part 11 - Intrinsic
		Safety "i"
CAN/CSA-E60079-15:02	-	Electrical Apparatus for Explosive Atmospheres, Part 15 – Type of
		Protection "n"



 Certificate:
 1675804 (LR 54227)
 Master Contract:
 173246

 Project:
 70136714
 Date Issued:
 2017-05-24

#### **MARKINGS**

Marking nameplate shall bear the following information:

- CSA Monogram;
- Submittor Identification;
- Model number;
- Serial number or date code;
- Electrical Rating/Entity Parameters
- Hazardous Location Designation;
- Reference to installation drawing number.
- The caution: "Warning Substitution of Components May Impair Intrinsic Safety";
- Temperature Code Rating
- Maximum ambient
- Year and Certificate Number followed by an indicator 'X'



## Supplement to Certificate of Compliance

**Certificate:** 1675804 **Master Contract:** 173246 (LR 54227)

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

Project	Date	Description
70136714	2017-05-24	Addition of a new window construction
1675804	2006-06-01	Correction - originally issued January 30, 2006
1675804	2006-01-30	Original Certification.