



1 **EU – Type Examination Certificate**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 **EU – Type Examination Certificate Number: KIWA 18ATEX0031 X Issue: 1**

4 **Product: Position Transmitter Type 4749**

5 **Manufacturer: SAMSON AKTIENGESELLSCHAFT**

6 **Address: Weismüllerstraße 3, 60314 Frankfurt
Germany**

7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Kiwa Nederland B.V., Notified Body number 0620 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.
The examination and test results are recorded in confidential ATEX Assessment Report No. 180600585.

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 60079-0 : 2012 + A11 : 2013 EN 60079-11 : 2012

10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU – Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:



II 2 G
II 2 D

Ex ia IIC T6...T4 Gb
Ex ia IIIC T85 °C Db

Kiwa Nederland B.V.
Unit Kiwa ExVision
Wilmsdorf 50
P.O. Box 137
7300 AC Apeldoorn
The Netherlands

Tel. +31 88 998 34 93
Fax +31 88 998 36 85
ExVision@kiwa.nl
www.kiwaexvision.com

Kiwa Nederland B.V.

Pieter van Breugel
Certification Officer

Issue date:

9 January 2019

First issue:

This certificate shall, as far as applicable, be revised before the date of cessation of presumption of conformity of (one of) the included standards above as communicated in the Official Journal of the European Union.

© Integral publication of this certificate in its entirety and without any change is allowed.

13 SCHEDULE

14 EU – Type Examination Certificate KIWA 18ATEX0031 X Issue No. 1

15.1 Description of Product

The Position Transmitter Type 4749 is mounted on control valves and converts the lifting or rotating movements of the valve drive into a 4-20 mA current signal.

The position transmitter enclosure is provided with a threaded cover and can be of aluminium or stainless steel.

Maximum ambient temperature for T6 and T85 °C: +55 °C

Maximum ambient temperature for T5: +70 °C

Maximum ambient temperature for T4: +80 °C

Minimum ambient temperature: -40 °C

The Position Transmitter enclosure provides a degree of protection of IP66 in accordance with EN 60529.

Type designation

4749-abcde

- a: Approvals
110 (Intrinsically safe ATEX)
- b: Options
0 (position transmitter 4 - 20 mA)
- c: Reserved
X (not safety relevant)
- d: Field wiring entry
0 (M20x1,5)
1 (NPT 1/2")
- e: Enclosure material
0 (aluminium)
1 (stainless steel)

15.2 Electrical Data

Supply and output circuit (terminals +31, -32):

in type of protection intrinsic safety Ex ia IIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$U_i = 28 \text{ V}$; $I_i = 115 \text{ mA}$; $P_i = 1,0 \text{ W}$; $C_i = 19,2 \text{ nF}$; $L_i = 0 \text{ mH}$

15.3 Instructions

The instructions provided with the product shall be followed in detail to assure safe operation.

16 ATEX Assessment Report Number

180600585.



13 **SCHEDULE**

14 **EU – Type Examination Certificate KIWA 18ATEX0031 X Issue No. 1**

17 **Specific Conditions of Use**

For the applicable ambient temperature range, refer to 15.

For EPL Db:

- The equipment shall be installed and maintained such that hazards caused by electrostatic discharge are excluded;
- Heat resisting cables and cable glands, suitable for a temperature of at least 20 K higher than the max. ambient temperature shall be used.

18 **Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at section 9.

19 **Drawings and Documents**

As listed in ATEX Assessment Report No. 180600585.

