



中国国家强制性产品认证证书



证书编号: 2021322307003632

认证委托人名称: SAMSON AKTIENGESELLSCHAFT

认证委托人地址: Weismuellerstr. 3, 60314 Frankfurt am Main, Germany

生产者名称: SAMSON AKTIENGESELLSCHAFT

生产者地址: Weismuellerstr. 3, 60314 Frankfurt am Main, Germany

生产企业名称: SAMSON REGULATION S.A.S

生产企业地址: 1 Rue Jean Corona, 69120 Vaulx-en-Velin, France

产品名称: 电磁阀

系列、规格、型号: 3967-111 系列

标 准: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2021 年 1 月 8 日

有效期至: 2026 年 1 月 7 日

首次发证日期: 2021 年 1 月 8 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322307003632

APPLICANT: SAMSON AKTIENGESELLSCHAFT
ADDRESS: Weismuellerstr. 3, 60314 Frankfurt am Main, Germany
MANUFACTURER: SAMSON AKTIENGESELLSCHAFT
ADDRESS: Weismuellerstr. 3, 60314 Frankfurt am Main, Germany
FACTORY: SAMSON REGULATION S.A.S
ADDRESS: 1 Rue Jean Corona, 69120 Vaulx-en-Velin, France

PRODUCTNAME: Solenoid Valve
SERIES,SPECIFICATION,MODEL: 3967-111 series
STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: January 8, 2021

Valid until: January 7, 2026

Date of original certification: January 8, 2021

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004369



中国国家强制性产品认证证书



SITIAs
Worldwide Access

证书编号: 2021322307003632

附 件

产品名称: 电磁阀

型号规格:

Solenoid valve type 3967

3 9 6 7 - a b c d e f g h i j k l m n o p
x x x x x x x x x x x x x x x x x

Ex-Protection

1 1 1 NEPSI/CCC Ex ia IIC T4 ~ T6 Gb, Ex iaD 21 T80
a b c

Nominal Signal

1 6 V DC
2 12 V DC
3 24 V DC

Reserved for pneumatic connection and mounting (Not safety relevant)

d e f g h i j k l m

Electrical connections

0 0 Without cable gland
0 1 Cable gland M16x1.5, black polyamide
1 2 Cable gland M16x1.5, blue polyamide
1 3 Cable gland M16x1.5, black polyamide (Ex e, CEAG)
1 4 Cable gland M16x1.5, nickel-plated brass
1 5 Cable gland M16x1.5, brass, blue
a o

Ingress protection IP

0 IP65
p

防爆标志: Ex ia IIC T4~T6 Gb
Ex iaD 21 T80

温度组别与使用环境温度的关系:

温度组别	T6 / T80	T5	T4
使用环境温度范围	-45°C~+60°C	-45°C~+70°C	-45°C~+80°C

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



SITIAs
Worldwide Access

证书编号: 2021322307003632

附 件

电气参数:

本安电气参数:

Un (DC)	6V	12V	24V
最高输入电压 U_i (V)	32	32	32
最大输入电流 I_i (mA)	150	150	150
最大输入功率 P_i (mW)	250	--	--
最大内部电容 C_i (μ F)	忽略不计		
最大内部电感 L_i (mH)	忽略不计		

批 准:



上海仪器仪表自控系统检验测试所有限公司