CERTIFICATE OF CONFORMITY



- 1. HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS
- 2. Certificate No:
- 3. Equipment: (Type Reference and Name)
- 4. Name of Listing Company:
- 5. Address of Listing Company:

FM21US0097 Type 3730-3 series TROVIS HART Positioner

Samson AG Weismuellerstrasse 3 Postfach 101901 Frankfurt D60314 Germany

6. The examination and test results are recorded in confidential report number:

PR459607 dated 18th October 2022

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM Class 3600:2022, FM Class 3610:2021, FM Class 3611:2021, FM Class 3810:2021, ANSI/ISA 60079-0:2020, ANSI/UL 60079-11:2018, ANSI/UL 60079-31:2015, ANSI/ISA 61010-1:2012, ANSI/UL 121201:2019, ANSI/IEC 60529:2020, NEMA 250:2008

8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

Certificate issued by:

arguestion

J/E. Marquedant VP, Manager - Electrical Systems 18 January 2023 Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>

F 347 (Apr 21)

OCPS Accrédité CCN





Vals

US Certificate Of Conformity No: FM21US0097

9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. Equipment Ratings:

Intrinsically Safe for Class I, II, III Division 1, Groups A, B, C, D, E, F, and G hazardous (classified) locations in accordance with drawing EB 8484-3, Intrinsically Safe for Class I, Zone 1, Group IIC hazardous (classified) locations in accordance with drawing EB 8484-3; Nonincendive for Class I, II, III Division 2, Groups A, B, C, D, F and G hazardous locations, indoors and outdoors (Type 4X, IP66) with an ambient temperature rating per the table in Section 12 below

11. The marking of the equipment shall include:

IS Class I, II, III, Division 1, Groups A, B, C, D, E, F, G; T* Ta*

IS Class I, Zone 1, AEx ia IIC T* Gb

NI Class I, II, III Division 2, Groups A, B, C, D, F, G; T* Ta*

Type 4X; IP66

For Entity and NIFW parameters – refer to document no. EB8484-3

T* - See below

12. Description of Equipment:

General - The Type TROVIS 3730-3 HART Positioner is a single acting positioner for attachment to pneumatic control valves. The positioner ensures a predetermined assignment of the valve position (controlled variable x) to the input signal (reference variable w). It compares the input signal received from a control system to the travel or rotational angle of the control valve and issues a corresponding output signal pressure (output variable y) for the pneumatic actuator.

Construction - The Type TROVIS 3730-3 HART Positioner mainly consists of the electronics part and one pneumatic module. The parts are assembled in an enclosure made of aluminium die cast or stainless-steel die cast. The enclosure has a cover with a polymeric inspection window. As an alternative to the polymeric material the window can be made from aluminium. The enclosure has an ingress protection rating of Type 4X and IP66

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





US Certificate Of Conformity No: FM21US0097

Thermal Ratings:

The correlation between temperature class and permissible ambient temperature range T_a is shown in Table 2.

Table 2:		
	Temperature class	Permissible ambient temperature T _a
	T4	-40 °C ≤ T _a ≤ + 80 °C
	Т6	-40 °C ≤ T _a ≤ + 55 °C

For operation with inductive limit switches used with $I_{max}/I_i = 52$ mA and Pi = 169 mW, the correlation between temperature class and permissible ambient temperature range is shown in Table 3.

Table 3:

Temperature class	Permissible ambient temperature T _a	
T4	-40 °C ≤ T _a ≤ + 70 °C	
T6	-40 °C ≤ Ta ≤ + 4 <mark>5</mark> °C	

FIVI Annrovals

Electrical Ratings:

Circuit	Signal circuit	Position	Inductive limit	Software limit
		transmitter	switches	switches
Circuit no.	1	2	3 and 4	5 and 6
Terminal no.	+11 / -12	+31 / -32	+41 / -42	+45 / -46
			and	and
			+51 / -52	+55 / -56
V _{max} or U _i	28 V	28 V	16 V	16 V
I _{max} or I _i	115 mA	115 mA	25 mA or 52 mA	52 mA
Pi	1 W	1 W	64 mW or 169 mW	169 mW
Ci	16.3 nF	11.1 nF	71.1 nF	12.2 nF
Li	negligible	negligible	100 µH	negligible
Rated values	I _N = 4 mA20 mA	U _N = 24 V DC	* U _N = 8.2 V	* U _N = 8.2 V
			Ri = 1 kΩ	Ri = 1 kΩ
Circuit	External position	Forced venting	Binary output	Binary input
	sensor		(NAMUR)	(24 V DC)
Circuit no.	7	8	9	10
Terminal no.	V_REF / PISTE /	+81 / -82	+83 / -84	+87 / -88
	GND			
V _{max} or U _i	4.8 V	28 V	16 V	28 V
I _{max} or I _i	64 mA	115 mA	52 mA	115 mA

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE



SCHEDULE

US Certificate Of Conformity No: FM21US0097

Pi	74 mW	1 W	169 mW	1 W
Ci		11.1 nF	12.2 nF	11.1 nF
Li		Negligible	Negligible	Negligible
Rated values		U _N = 24 V DC	* U _N = 8.2 V R _i = 1 kΩ	U _N = 24 V DC
	ΓIVI	AUU	IUVC	112

pprovals

TROVIS 3730-3-1300efghijklmnopqrst

- e = Slot A Options: 0, 1 or 2
- f = Slot B Options: 0, 1, 2 or 3
- g = Slot C Options: 0, 2, 3, 4 or 5
- h = Slot D Options: 0, 1, 2, 3, 4, 5 or 6
- i = reserved: not safety relevant
- j = reserved: not safety relevant
- k = Emergency shutdown: not safety relevant
- I = Electrical Connection: 0, 1 or 2
- m = reserved: not safety relevant
- n = Housing material: 0 or 1
- o = Cover: 1 or 2
- pq = Housing version: not safety relevant
- r = Additional Approval: not safety relevant
- s = Ship Approval: not safety relevant
- t = Permissible ambient temperature: not safety relevant

13. Specific Conditions of Use:

None

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





US Certificate Of Conformity No: FM21US0097

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description	0
18 th October 2022	Original Issue.	
18 th January 2023	Supplement 1: Report Reference: RR235223 dated 18 th January 2023. Description of the Change: Typos corrected in Section 12 (Descripti	on of Equipment)

FM Approvals

FM Approvals

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE