



Certificate: 1709815

Master Contract: 173246

Project: 80226857

Date Issued: 2025-03-03

APPLICABLE REQUIREMENTS

CSA C22.2 No. 25-1966 (First Edition) - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations - General Instruction No 1

CSA C22.2 No. 30-M1986 - Third Edition - Explosion-proof enclosures for use in class I hazardous locations - General Instruction No. 1: November 1986; General Instruction No. 2: November 1988

CSA C22.2 No. 94-M91 - Fourth Edition - Special Purpose Enclosures Industrial Products -Fourth Edition

CAN/CSA C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

Markings

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The products listed are eligible to bear the CSA Mark, without any adjacent indicators, indicating that products have been manufactured to the requirements of Canadian Standards.

- CSA Monogram
- Company name or Master Contract Model number
- Serial number
- May be optionally marked with CSA Certificate No: CSA.05.1709815
- Electrical rating
- Hazardous locations designation
- Special purpose enclosure designation, "TYPE 4X" Max Ambient
- Temperature Code Rating " Temp. Code
- ISO 3864 Symbol B.3.1  or ISO 7000 symbol 0434  (triangle with exclamation point)



Certificate: 1709815

Project: 80226857

Master Contract: 173246

Date Issued: 2025-03-03

The following warnings shall be included in the instruction manual in both English and French:

- "Use supply wires rated at least 90°C"
- "Caution keeping cover tight while circuits are live"
- "Seal not required"



Certificate: 1709815


Master Contract: 173246

Project: 80226857

Date Issued: 2025-03-03

Notes:

Products certified under Class(es) C225802 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1709815

Master Contract: 173246

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80226857	2025-03-03	Update to Report 1709815 to address issues noted in FC #173247, FIR dated May 13, 2024 for revised construction drawings.
80081901	2022-02-10	Update to Report 1709815 to address (FC# 173247) FIR dated December 8, 2020
1709815	2005-10-04	Original Certification of model 3731-.23 Positioner Class I, Div 1+2 Groups B,C,D T6...T4 Class II, Div 1+2 Groups E,F,G, Class III Class 1, Zone 1, IIB+H2 T6...T4