



Certificate of Compliance

Certificate: 1613095

Master Contract: 173246

Project: 1613095

Date Issued: 2005/02/11

Issued to: Samson AG

Mess- Und Regeltechnik
Department E71
Weismuellerstrasse 3
Frankfurt, 60314
Germany
Attention: Mr. Holger Pflug

The products listed below are eligible to bear the CSA Mark shown



Issued by: Jimmy Lu

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For
Hazardous Locations

Ex ia IIC T6; Class I, Zone 0:

Class II, Groups E, F and G:

Model 3730-03 Electro-pneumatic Positioner; Temperature Code T6 at ambient of +60°C, T5 at +70°C and T4 at +80°C; Type 4 Enclosure; Intrinsically safe when installed per Samson AG installation drawing EB 8384-0 EN.



Certificate: 1613095

Master Contract: 173246

Project: 1613095

Date Issued: 2005/02/11

Note: only versions with cable gland and connectors per drawing 1050-0296S1 are qualified for Class II.

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Ex nA II T6; Class I, Zone 2:

Class II, Division 2, Groups E, F and G:

Model 3730-03 Electro-pneumatic Positioner, input rated 30VDC, 4-20mA max; Temperature Code T6 at ambient of +60°C, T5 at +70°C and T4 at +80°C; Type 4 Enclosure.

Note: only versions with cable gland and connectors per drawing 1050-0296S1 are qualified for Class II.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA-C22.2 No.142-M1987 - Process Control Equipment

CAN/CSA-E60079-0:02 - Electrical Apparatus for Explosive Atmospheres Part 0 - General Requirements

CAN/CSA-E60079-11:02 - Electrical Apparatus for Explosive Atmospheres Part 11 - Intrinsic Safety "i"

CAN/CSA E60079-15:02 - Electrical Apparatus for Explosive Atmospheres Part 15 - Type of Protection "n"

MARKINGS

- CSA Monogram;
- Submitter identification;
- Model number;
- Serial number or date code;
- Electrical rating/Entity parameters;
- Hazardous location designation;
- Reference to installation drawing number;



Certificate: 1613095

Master Contract: 173246

Project: 1613095

Date Issued: 2005/02/11

-
- The Caution: "Warning - Substitution of Components May Impair Intrinsic Safety";
 - Temperature code rating;
 - Maximum ambient; and
 - Certification year and Certificate number followed by an indicator 'X'

SPECIAL CONDITION FOR SAFE USE

Model 3730-03 Electro-pneumatic Positioner must be installed per SAMSON AG control installation drawing EB 8384-0 EN.



Supplement to Certificate of Compliance

Certificate: 1613095

Master Contract: 173246

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1613095	2005/02/11	Model 3730-03 Electro-pneumatic Positioner - Original Certification

Supplement Notes