



# Certificate of Compliance

**Certificate:** 1471157 (LR 54227-18)

**Master Contract:** 173246

**Project:** 2774956

**Date Issued:** November 14, 2014

**Issued to:** Samson AG

Mess- und Regeltechnik  
Department E8  
Weismuellerstrasse 3  
Frankfurt, 60314  
Germany  
Attention: Tomislav Varga

*The products listed below are eligible to bear the CSA Mark shown*



*D. Simpson*

**Issued by:** D. Simpson

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III:

Electro-pneumatic converter, Series 6116-3, rated input 0-20 or 4-20mA dc, Encl 4 rated; ambient -45°C to +70°C. Temperature Code T6.

## **APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

## **MARKINGS**

- Company Name.

- Model number.



**Certificate:** 1471157 (LR 54227-18)

**Master Contract:** 173246

**Project:** 2774956

**Date Issued:** November 14, 2014

---

- Serial number.
- Electrical rating.
- Hazardous Location Designation.
- Special purpose enclosure designation, "Type 4".
- CSA Monogram.
- Caution re keeping over tight while circuits are live.
- Ambient temperature
- Temperature Code