

1

UNITED KINGDOM CONFORMITY ASSESSMENT

# TYPE EXAMINATION CERTIFICATE



2 Equipment or Protective systems intended for use in Potentially Explosive Atmospheres –  
UKSI 2016:1107 (as amended)

3 Type Examination Certificate No: FM21UKEX0203X

4 Equipment or protective system: Model Type 3730-4/5, TROVIS 3730-1,  
(Type Reference and Name) TROVIS 3730-3 and TROVIS 3793

5 Name of Applicant: Samson AG

6 Address of Applicant: Weismuellerstrasse 3  
Postfach 101901  
Frankfurt D60314  
Germany

7 This equipment or protective system and any acceptable variation thereto is specified in the  
schedule to this certificate and documents therein referred to.

8 FM Approvals Ltd, certifies that this product has been found to comply with the Essential Health  
and Safety Requirements relating to the design and construction of products intended for use in  
potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in confidential report number:

PR459607 dated 18<sup>th</sup> October 2022

9 Compliance with the Essential Health and Safety Requirements, with the exception of those  
identified in item 15 of the schedule to this certificate, has been assessed by compliance with the  
following documents:

EN IEC 60079-0:2018, EN IEC 60079-7:2015+A1:2018, EN 60079-31:2014,  
EN 60529:1991+A1:2000+A2:2013

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to  
specific conditions of use specified in the schedule to this certificate.

11 This Type Examination certificate relates only to the design, examination and tests of the specified  
equipment or protective system in accordance with the Regulations. Further requirements of the  
Regulations apply to the manufacturing process and supply of this product. These are not covered  
by this certificate.

12 The marking of the equipment or protective system shall include:



See Annex for marking details

**Victor Aluko-Oginni**  
Certification Manager, FM Approvals Ltd.

Issue date: 24<sup>th</sup> January 2023

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals Ltd, Voyager Place, Maidenhead, Berkshire, SL6 2PJ, United Kingdom  
T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: [atex@fmaprovals.com](mailto:atex@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)



0259

Page 1 of 8

# SCHEDULE

to Type Examination Certificate No. FM21UKEX0203X

## 13 Description of Equipment or Protective System:

### TROVIS 3730-1

**General** – The TROVIS 3730-1 Positioner is a single acting positioner for attachment to pneumatic control valves. The positioner mainly consists of a non-contact travel sensor system, an i/p converter and the electronics with the microcontroller. The valve position is transmitted either as an angle of rotation or a travel to the pick-up lever, from there to the travel sensor and forwarded to the microcontroller. The PID algorithm in the microcontroller compares the valve position measured by the travel sensor to the 4 to 20 mA DC control signal issued by the control system after it has been converted by the AD converter. In case of a set point deviation, the i/p converter causes the actuator to be either vented or filled with air. As a result, the closure member of the valve is moved to the position determined by the reference variable. The pneumatic module is supplied with supply air and the flow rate of the module's output can be restricted by software

**Construction** - The Type TROVIS 3730-1 Positioner mainly consists of the electronics part. The parts are assembled in an enclosure made of aluminium die cast or stainless-steel die cast. The enclosure has a cover with a polymeric inspection window. As an alternative to the polymeric material, the window can be made from aluminium. The enclosure has an ingress protection rating of IP66

See Annex for model code, thermal and electrical values.

### TROVIS 3730-3

**General** - The Type TROVIS 3730-3 HART Positioner is a single acting positioner for attachment to pneumatic control valves. The positioner ensures a predetermined assignment of the valve position (controlled variable x) to the input signal (reference variable w). It compares the input signal received from a control system to the travel or rotational angle of the control valve and issues a corresponding output signal pressure (output variable y) for the pneumatic actuator.

**Construction** - The Type TROVIS 3730-3 HART Positioner mainly consists of the electronics part and one pneumatic module. The parts are assembled in an enclosure made of aluminium die cast or stainless-steel die cast. The enclosure has a cover with a polymeric inspection window. As an alternative to the polymeric material the window can be made from aluminium. The enclosure has an ingress protection rating of IP66

See Annex for model code, thermal and electrical values.

### 3730-4/5

**General** - The positioners type 3730-41, 3730-51, 3730-45 and 3730-55 are communication-capable, bus-powered field devices which are used to assign a valve position to a control signal. The bus interface connection (bus-coupling) can be performed according to the FISCO-concept for both specifications, Profibus PA and Foundation<sup>TM</sup> Fieldbus. They are mounted onto levitation and slewing actuators. Non-flammable media are used as pneumatic auxiliary power. The equipment is intended for the application inside the hazardous area.

The positioners type 3730-48 and 3730-58 are communication-capable, bus powered field devices which are used to assign a valve position to a control signal. They are mounted onto levitation and slewing actuators. Non-flammable media are used as pneumatic auxiliary power. The equipment is intended for the application inside the hazardous area.

**Construction** - The Type 3730-4/5 Positioner mainly consists of the electronics part. The parts are assembled in an enclosure made of aluminium die cast or stainless-steel die cast. The enclosure has a cover with a polymeric inspection window. As an alternative to the polymeric material, the window can be made from aluminium. The enclosure has an ingress protection rating of Type 4X and IP66

See Annex for model code, thermal and electrical values.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE

to Type Examination Certificate No. FM21UKEX0203X

## **TROVIS / TROVIS SAFE 3793**

**General** - The Type 3793 HART Positioner is a single or double acting positioner for attachment to pneumatic control valves. The positioner ensures a pre-determined assignment of the valve position to the input signal. It compares the input signal received from a control system to the travel or rotational angle of the control valve and issues a corresponding output signal pressure for the pneumatic actuator

**Construction** - The 3793 HART Transmitter Positioner consists of the electronic part and one or two pneumatic modules. The parts are assembled in an enclosure made of aluminium die cast or stainless-steel die cast. The enclosure has a cover with a polymeric inspection window. As an alternative to the polymeric material the window can be made from aluminium. The enclosure has an ingress protection rating of IP66

See Annex for model code, thermal and electrical values.

### 14 **Specific Conditions of Use:**

See Annex for Specific Conditions of Use

### 15 **Essential Health and Safety Requirements:**

In addition to the Essential Health and Safety Requirements covered by the standards listed at item 9, all other requirements are demonstrated in the confidential report identified in item 8.

### 16 **Test and Assessment Procedure and Conditions:**

This Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

Whilst this certificate may be used in support of a manufacturer's claim for UKCA Marking, FM Approvals Ltd accepts no responsibility for the compliance of the equipment against all applicable Regulations in all applications.

This Certificate has been issued in accordance with FM Approvals Ltd's UKCA Certification Scheme.

### 17 **Schedule Drawings**

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Approved Body.

### 18 **Certificate History**

Details of the supplements to this certificate are described below:

Date	Description
20 <sup>th</sup> October 2022	Original Issue.
24 <sup>th</sup> January 2023	<u>Supplement 1:</u> Report Reference: RR235223 dated 18 <sup>th</sup> January 2023. Description of the Change: "HART" removed from TROVIS 3730-1 and other Typos corrected in Section 13 (Description of Equipment or Protective System). No change to the CDL.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE



Member of the FM Global Group

to Type Examination Certificate No. FM21UKEX0203X

## **ANNEX**

**Positioner TROVIS 3730-1-858defghijklmno**

### Equipment Markings

II 3G Ex ec IIC T\* Gc

### Electrical Ratings

Circuit	Signal circuit	Position transmitter	Inductive limit switches	Software limit switches
<b>Circuit no.</b>	1	2	3 and 4	5 and 6
<b>Terminal no.</b>	+11 / -12	+31 / -32	+41 / -42 and +51 / -52	+45 / -46 and +55 / -56
<b>Rated values</b>	$I_N = 4 \text{ mA} \dots 20 \text{ mA}$	$U_N = 24 \text{ V DC}$	* $U_N = 8.2 \text{ V}$ $R_i = 1 \text{ k}\Omega$	* $U_N = 8.2 \text{ V}$ $R_i = 1 \text{ k}\Omega$

### Thermal Ratings

The correlation between temperature class and permissible ambient temperature range  $T_a$  is shown in Table 2.

**Table 2:**

Temperature class	Permissible ambient temperature $T_a$
<b>T4</b>	$-40 \text{ }^\circ\text{C} \leq T_a \leq +80 \text{ }^\circ\text{C}$
<b>T6</b>	$-40 \text{ }^\circ\text{C} \leq T_a \leq +55 \text{ }^\circ\text{C}$

For operation with inductive limit switches used with  $I_{\max}/I_i = 52 \text{ mA}$  and  $P_i = 169 \text{ mW}$ , the correlation between temperature class and permissible ambient temperature range is shown in Table 3.

**Table 3:**

Temperature class	Permissible ambient temperature $T_a$
<b>T4</b>	$-40 \text{ }^\circ\text{C} \leq T_a \leq +70 \text{ }^\circ\text{C}$
<b>T6</b>	$-40 \text{ }^\circ\text{C} \leq T_a \leq +45 \text{ }^\circ\text{C}$

### Model Code

- d = function: not safety relevant
- e = Slot B Options: 0, or 1
- f = Slot C Options: 0, 2, 3 or 4
- g = reserved: not safety relevant
- h = Electrical connection: 0 or 1
- i = Housing material: 0 or 1
- j = Cover: 1 or 2
- kl = Housing version: not safety relevant
- m = Additional Approval: not safety relevant
- n = Ship Approval: not safety relevant
- o = Permissible ambient temperature: not safety relevant

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals Ltd. Voyager Place, Maidenhead, Berkshire, SL6 2PJ. United Kingdom  
T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: [atex@fmapprovals.com](mailto:atex@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Member of the FM Global Group

to Type Examination Certificate No. FM21UKEX0203X

**Positioner TROVIS 3730-3-858defghijklmnopqrst**

## Equipment Markings

II 3G Ex ec IIC T\* Gc

## Electrical Ratings

Circuit	Signal circuit	Position transmitter	Inductive limit switches	Software limit switches
Circuit no.	1	2	3 and 4	5 and 6
Terminal no.	+11 / -12	+31 / -32	+41 / -42 and +51 / -52	+45 / -46 and +55 / -56
Rated values	$I_N = 4 \text{ mA} \dots 20 \text{ mA}$	$U_N = 24 \text{ V DC}$	* $U_N = 8.2 \text{ V}$ $R_i = 1 \text{ k}\Omega$	* $U_N = 8.2 \text{ V}$ $R_i = 1 \text{ k}\Omega$
Circuit	External position sensor	Forced venting	Binary output (NAMUR)	Binary input (24 V DC)
Circuit no.	7	8	9	10
Terminal no.	V_REF / PISTE / GND	+81 / -82	+83 / -84	+87 / -88
Rated values		$U_N = 24 \text{ V DC}$	* $U_N = 8.2 \text{ V}$ $R_i = 1 \text{ k}\Omega$	$U_N = 24 \text{ V DC}$

## Thermal Ratings

The correlation between temperature class and permissible ambient temperature range  $T_a$  is shown in Table 2.

Table 2:

Temperature class	Permissible ambient temperature $T_a$
T4	$-40 \text{ }^\circ\text{C} \leq T_a \leq +80 \text{ }^\circ\text{C}$
T6	$-40 \text{ }^\circ\text{C} \leq T_a \leq +55 \text{ }^\circ\text{C}$

For operation with inductive limit switches used with  $I_{max}/I_i = 52 \text{ mA}$  and  $P_i = 169 \text{ mW}$ , the correlation between temperature class and permissible ambient temperature range is shown in Table 3.

Table 3:

Temperature class	Permissible ambient temperature $T_a$
T4	$-40 \text{ }^\circ\text{C} \leq T_a \leq +70 \text{ }^\circ\text{C}$
T6	$-40 \text{ }^\circ\text{C} \leq T_a \leq +45 \text{ }^\circ\text{C}$

Operation with External position sensor I

Table 4:

Temperature class	Permissible ambient temperature $T_a$
T4	$-30 \text{ }^\circ\text{C} \leq T_a \leq +80 \text{ }^\circ\text{C}$
T6	$-30 \text{ }^\circ\text{C} \leq T_a \leq +55 \text{ }^\circ\text{C}$

## Model Code

d = function: not safety relevant

e = Slot A Options: 0, 1 or 2

f = Slot B Options: 0, 1, 2 or 3

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals Ltd. Voyager Place, Maidenhead, Berkshire, SL6 2PJ. United Kingdom  
T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: [atex@fmapprovals.com](mailto:atex@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Member of the FM Global Group

to Type Examination Certificate No. FM21UKEX0203X

- g = Slot C Options: 0, 2, 3, 4 or 5
- h = Slot D Options: 0, 1, 2, 3, 4, 5 or 6
- i = reserved: not safety relevant
- j = reserved: not safety relevant
- k = Emergency shutdown: not safety relevant
- l = Electrical Connection: 0, 1 or 2
- m = reserved: not safety relevant
- n = Housing material: 0 or 1
- o = Cover: 1 or 2
- pq = Housing version: not safety relevant
- r = Additional Approval: not safety relevant
- s = Ship Approval: not safety relevant
- t = Permissible ambient temperature: not safety relevant

**Positioner 3730-48/58cdefghijk**

**Equipment markings**

II 3G Ex ec IIC T\* Gc

II 3D Ex tc IIIC T80°C Dc

**Electrical Ratings**

Circuit	Signal Circuit Foundation™ Fieldbus	Signal Circuit FISCO (PROFIBUS PA)	Inductive limit switches	Forced venting
<b>Circuit no.</b>	1	2	3	4
<b>Terminal no.</b>	+11 / -12	+11 / -12	+41 / -42	+81 / -82
<b>Rated values</b>			* U <sub>N</sub> = 8.2 V R <sub>i</sub> = 1 kΩ	
<b>Circuit</b>	<b>Binary input (24 V DC)</b>			
<b>Circuit no.</b>	5			
<b>Terminal no.</b>	+87 / -88			
<b>V<sub>max</sub> or U<sub>i</sub></b>	30 V			
<b>I<sub>max</sub> or I<sub>i</sub></b>	100 mA			
<b>P<sub>i</sub></b>	1 W			
<b>C<sub>i</sub></b>	Negligible			
<b>L<sub>i</sub></b>	Negligible			
<b>Rated values</b>	U <sub>N</sub> = 24 V DC			

**Thermal Ratings**

The correlation between temperature class and permissible ambient temperature range T<sub>a</sub> is shown in Table 2.

**Table 2:**

Temperature class	Permissible ambient temperature T <sub>a</sub>
<b>T4</b>	-40 °C ≤ T <sub>a</sub> ≤ + 80 °C
<b>T6</b>	-40 °C ≤ T <sub>a</sub> ≤ + 55 °C

For operation with inductive limit switches used with I<sub>max</sub>/I<sub>i</sub> = 52 mA, P<sub>i</sub> = 169 mW and I<sub>max</sub>/I<sub>i</sub> = 25 mA, P<sub>i</sub> = 64 mW,  
**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE



Member of the FM Global Group

to Type Examination Certificate No. FM21UKEX0203X

the correlation between temperature class and permissible ambient temperature range is shown in Table 3.

**Table 3:**

Temperature class	Permissible ambient temperature T <sub>a</sub>	I <sub>i</sub> / P <sub>i</sub>
T4	-40 °C ≤ T <sub>a</sub> ≤ + 75 °C	52 mA / 169 mW
T6	-40 °C ≤ T <sub>a</sub> ≤ + 45 °C	
T4	-40 °C ≤ T <sub>a</sub> ≤ + 80 °C	25 mA / 64 mW
T6	-40 °C ≤ T <sub>a</sub> ≤ + 55 °C	

**The permissible ambient temperature range T<sub>a</sub> for dust group IIIC is -40 °C ≤ T<sub>a</sub> ≤ + 80 °C**

**Model Code**

- c = Inductive limit contact: 0 or 1
- d = solenoid valve: 0 or 4
- e = not safety relevant
- f = Positions sensor: 0 or 1
- g = Leakage sensor: 0 or 2
- h = Binary input: 0 or 1
- i = Diagnostics: 4
- j = Housing material: 0 or 1
- k = Connection: 1+2 or 5+6

**Specific Conditions of Use**

1. For the applications in dust group IIIC, the cable glands and blanking plugs supplied must be replaced with certified ones. The cable glands and blanked plugs must be suitable for the corresponding ambient temperatures and have a degree of protection of at least IP 54.

***Positioner TROVIS / TROVIS SAFE 3793-858efghijklmnopq***

**Equipment Markings**

II 3G Ex ec IIC T\* Gc

**Electrical Ratings**

Circuit	Signal circuit	Position transmitter	Inductive limit switches	Software limit switches
<b>Circuit no.</b>	1	2	3 and 4	5 and 6
<b>Terminal no.</b>	+11 / -12	+31 / -32	+41 / -42 and +51 / -52	+45 / -46 and +55 / -56
<b>Rated values</b>	I <sub>N</sub> = 4 mA...20 mA	U <sub>N</sub> = 24 V DC	* U <sub>N</sub> = 8.2 V, R <sub>i</sub> = 1 kΩ	* U <sub>N</sub> = 8.2 V, R <sub>i</sub> = 1 kΩ

Circuit	Mechanical limit switches	Forced venting	Binary output (NAMUR)	Binary input (24 V DC)
<b>Circuit no.</b>	7 and 8	9	10	11
<b>Terminal no.</b>	47 / 48 / 49 and 57 / 58 / 59	+81 / -82	+83 / -84	+87 / -88
<b>Rated values</b>	U <sub>N</sub> = 28 V DC	U <sub>N</sub> = 24 V DC	* U <sub>N</sub> = 8.2 V, R <sub>i</sub> = 1 kΩ	U <sub>N</sub> = 24 V DC

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals Ltd. Voyager Place, Maidenhead, Berkshire, SL6 2PJ. United Kingdom  
 T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: [atex@fmapprovals.com](mailto:atex@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Member of the FM Global Group

to Type Examination Certificate No. FM21UKEX0203X

Circuit	Analog input	Servo drive (AMR) and external position sensor I	External position sensor II	Binary output (contact) (24 V DC)
<b>Circuit no.</b>	12	13	14	15
<b>Terminal no.</b>	+17 / -18	21 / 22 /23 / 24	+15 / -16	+85 / -86
<b>Rated values</b>	$U_N = 3.5 \text{ V DC}$		$U_N = 24 \text{ V DC}$	$U_N = 24 \text{ V DC}$

### Thermal Ratings

The correlation between the temperature class and permissible ambient temperature range  $T_a$  is shown in Table 2.

**Table 2:**

Temperature class	Permissible ambient temperature $T_a$
<b>T4</b>	$-40 \text{ °C} \leq T_a \leq + 80 \text{ °C}$
<b>T6</b>	$-40 \text{ °C} \leq T_a \leq + 55 \text{ °C}$

For operation with inductive limit switches used with  $I_{max}/I_i = 52 \text{ mA}$  and  $P_i = 169 \text{ mW}$ , the correlation between the temperature class and permissible ambient temperature range is shown in Table 3.

**Table 3:**

Temperature class	Permissible ambient temperature $T_a$
<b>T4</b>	$-40 \text{ °C} \leq T_a \leq + 70 \text{ °C}$
<b>T6</b>	$-40 \text{ °C} \leq T_a \leq + 45 \text{ °C}$

Operation with External position sensor I

**Table 3:**

Temperature class	Permissible ambient temperature $T_a$
<b>T4</b>	$-30 \text{ °C} \leq T_a \leq + 80 \text{ °C}$
<b>T6</b>	$-30 \text{ °C} \leq T_a \leq + 55 \text{ °C}$

### Model Code

- e = not safety relevant
- fg = not safety relevant
- hi = Option module 1: 00, 10, 40, 45, 65, 80 or 90
- jk = Option module 2: 00, 10, 21, 40, 50, 51, 80, 15, 16, 30, 60, 65 or 90
- l = Pressure sensor: 0, 1 or 2
- m = Electrical connections: 0 or 1
- n = Housing material: 0, 1 or 2
- o = Special application: not safety relevant
- p = Additional approvals: not safety relevant
- q = Ambient temperature: not safety relevant

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals Ltd. Voyager Place, Maidenhead, Berkshire, SL6 2PJ. United Kingdom  
 T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: [atex@fmapprovals.com](mailto:atex@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)